



Kyuquot Power Ltd.
4248 Broughton Avenue
Niagara Falls, Ontario L2E 3K6
Tel (604) 688-8271

Via Email

October 30, 2024

Mr. Patrick Wruck, Commission Secretary
British Columbia Utilities Commission
Suite 410, 900 Howe Street
Vancouver, BC V6Z 2N3

**Kyuquot Power Ltd. (“KPL”)
F2024 Annual Report to the British Columbia Utilities Commission
Reliability Metrics**

As part of the Annual Reporting filings, British Columbia Utilities Commission (“BCUC”) has requested Kyuquot Power Ltd. (“KPL”) to provide the table below for the past three (3) fiscal years.

**KPL F2021 – F2023
Reliability Metrics**

	F2022	F2023	F2024
SAIDI ¹ (hours)	361	112	130
SAIFI ²	11.9	10	8

Yours truly,
Kyuquot Power Ltd.

Original signed by:

Greg Sunell, Consultant to KPL.

cc: Daniel Russell, President, daniel.russell@synex.com
Maritza Ona, Assistant Accountant, mona@synex.com

¹ System Average Interruption Duration Index (SAIDI)

² System Average Interruption Frequency Index (SAIFI)